


Female Union Elbow

Manufacturing Standards: DVGW round tubes manufactured according to DIN-1988/2463 EN 10312. Tubes with DVGW TS 225 authorization correspond to the requirements of the DVGW W 541 worksheet. **Certificates:** Standard stock lengths of 6 meters. Product certificates are provided, if required, according to the following standard: EN 10204/3.1.B or DIN 50049. **Grade:** Austenitic, series 304 - L, 316-L. **Dimensions:** Manufactured in diameters from 15 mm to 108 mm. Wall thickness of 1 to 2 mm. **Applications:** DVGW W 541 tubes are used for transport of chlorinated drinking water up to 2 mg / l in AISI-316 L grade water pipes. The AISI-304 L grade is used in compressed air systems.



Technical information

DN	Dimensiones			Art.
	Tubo Ø	L	L1	
12	15-½"	57	37	3803
15	18-½"	57	39	3804
20	22-¾"	60	46	3805
25	25-1"	67	54	3806
32	32-1¼"	75	63	3807