

Bend 45° Female-Female

Manufacturing standards: DVGW round tubes manufactured according to DIN-1988/2463 EN 10312 Tubes with DVGW TS 225 approval correspond to the requirements of DVGW worksheet W 541

Certificates: Standard supply in lengths of 6 m. We provide product certificates if required, according to the following standard: EN 10204/3.1.B or DIN 50049.

Grades: Austenitic grades types 304-L, 316-L

Dimensions: Manufactured in diameters from 15 mm to 108 mm. Wall thicknesses from 1 to 2 mm

Applications: DVGW W 541 tubes are used in the transport of drinking and chlorinated water up to 2 mg/l in water with AISI-316 L pipes, AISI-304 L quality is used in compressed air installations.



Technical information

DN	Dimensiones		Art.
	Tubo Ø	L	
12	15	36	0602
15	18	37	0603
20	22	42	0604
25	28	48	0605
32	35	43	2606
40	42	51	2607
50	54	62	2608
65	76,1	97	2609
80	88,9	112	2610
100	108	139	2611