

Bend 45° Male-Female

Manufacturing standards: DVGW round tubes manufactured according to DIN-1988/2463 EN 10312 Tubes with DVGW TS 225 approval correspond to the requirements of DVGW worksheet W 541

Certificates: Standard supply in lengths of 6 m. We provide product certificates if required, according to the following standard: EN 10204/3.1.B or DIN 50049.

Grades: Austenitic grades types 304-L, 316-L

Dimensions: Manufactured in diameters from 15 mm to 108 mm. Wall thicknesses from 1 to 2 mm

Applications: DVGW W 541 tubes are used in the transport of drinking and chlorinated water up to 2 mg/l in water with AISI-316 L pipes, AISI-304 L quality is used in compressed air installations.



Technical information

DN	Dimensiones			Art.
	Tubo Ø	L	L1	
15	15	45	36	0702
15	18	42	37	0703
20	22	52	42	0704
25	28	56	48	0705
32	35	53	43	2706
40	42	61	51	2707
50	54	73	62	2708
65	76,1	111	97	2709
80	88,9	13	112	2710
100	108	157	139	2711