


## 2-Piece Adapter

- **Manufacturing standards:** DVGW round tubes manufactured according to DIN-1988/2463 EN 10312 Tubes with DVGW TS 225 approval correspond to the requirements of DVGW worksheet W 541
- **Certificates:** Standard supply in lengths of 6 m. We provide product certificates if required, according to the following standard: EN 10204/3.1.B or DIN 50049.
- **Grades:** Austenitic grades types 304-L, 316-L
- **Dimensions:** Manufactured in diameters from 15 mm to 108 mm. Wall thicknesses from 1 to 2 mm
- **Applications:** DVGW W 541 tubes are used in the transport of drinking and chlorinated water up to 2 mg/l in water with AISI-316 L pipes, AISI-304 L quality is used in compressed air installations.



### Technical information

| DN | Dimensiones |    | Art. |
|----|-------------|----|------|
|    | Tubo Ø      | L  |      |
| 12 | 15-½"       | 51 | 5042 |
| 12 | 15-¾"       | 37 | 5032 |
| 12 | 15-1¼"      | 43 | 5072 |
| 15 | 18-¾"       | 37 | 5033 |
| 15 | 18-1½"      | 44 | 5043 |
| 20 | 22-1"       | 40 | 5034 |
| 20 | 22-1¼"      | 43 | 5044 |
| 20 | 22-1½"      | 44 | 5045 |
| 25 | 28-1"       | 40 | 5046 |
| 25 | 28 1¼"      | 44 | 5035 |
| 25 | 28-1½"      | 46 | 5036 |
| 32 | 35-1½"      | 48 | 5047 |
| 40 | 42-1¼"      | 52 | 5037 |
| 50 | 54-2 3/8"   | 58 | 5038 |