

## Female Union


**Manufacturing standards:** DVGW round tubes manufactured according to DIN-1988/2463 EN 10312 Tubes with DVGW TS 225 approval correspond to the requirements of DVGW worksheet W 541

**Certificates:** Standard supply in lengths of 6 m. We provide product certificates if required, according to the following standard: EN 10204/3.1.B or DIN 50049.

**Grades:** Austenitic grades types 304-L, 316-L

**Dimensions:** Manufactured in diameters from 15 mm to 108 mm. Wall thicknesses from 1 to 2 mm

**Applications:** DVGW W 541 tubes are used in the transport of drinking and chlorinated water up to 2 mg/l in water with AISI-316 L pipes, AISI-304 L quality is used in compressed air installations.



### Technical information

DN	Dimensiones		Art.
	Tubo Ø	L	
12-15	15-½"	37	1802
12-20	15-¾"	38	1823
15-15	18-½"	37	1803
15-20	18-¾"	38	1804
20-15	22-½"	36	1805
20-20	22-¾"	39	1806
20-25	22-1"	42	1824
25-15	28-½"	38	1807
25-20	28-¾"	39	1819
25-25	28-1"	44	1809
25-32	28-1¼"	46	1825
32-25	35-1"	45	1820
32-32	35-1¼"	49	1811
32-40	35-1½"	49	1826
40-32	42-1¼"	51	1821
40-40	42-1½"	53	1814

50-40	54-1½"	58	1822
50-50	54-2"	62	1818