


## Male Union Elbow

**Manufacturing Standards:** DVGW round tubes manufactured according to DIN-1988/2463 EN 10312. Tubes with DVGW TS 225 authorization correspond to the requirements of the DVGW W 541 worksheet **Certificates:** Standard stock lengths of 6 meters. Product certificates are provided, if required, according to the following standard: EN 10204/3.1.B or DIN 50049. **Grade:** Austenitic, series 304 - L, 316-L **Dimensions:** Manufactured in diameters from 15 mm to 108 mm. Wall thickness of 1 to 2 mm **Applications:** DVGW W 541 tubes are used for transport of chlorinated drinking water up to 2 mg / l in AISI-316 L grade water pipes. The AISI-304 L grade is used in compressed air systems.



### Technical information

DN	Dimensiones			Art.
	Tubo Ø	L	L1	
12	15-½"	57	37	3833
15	18-½"	57	39	3834
20	22-¾"	60	46	3835
25	28-1"	67	54	3836
32	35-1¼"	75	63	3837
40	42-1½"	83	67	3838
50	54-2"	94	78	3839