

Bend 90° Male-Female

Manufacturing standards: DVGW round tubes manufactured according to DIN-1988/2463 EN 10312 Tubes with DVGW TS 225 approval correspond to the requirements of DVGW worksheet W 541

Certificates: Standard supply in lengths of 6 m. We provide product certificates if required, according to the following standard: EN 10204/3.1.B or DIN 50049.

Grades: Austenitic grades types 304-L, 316-L

Dimensions: Manufactured in diameters from 15 mm to 108 mm. Wall thicknesses from 1 to 2 mm

Applications: DVGW W 541 tubes are used in the transport of drinking and chlorinated water up to 2 mg/l in water with AISI-316 L pipes, AISI-304 L quality is used in compressed air installations.



Technical information

DN	Dimensiones				Art.
	Tubo Ø	L	L1		
12	15	59	49	0302	
15	18	61	53	0303	
20	22	70	61	0304	
25	28	79	72	0305	
32	35	77	68	3306	
40	42	90	80	3307	
50	54	111	100	3308	
65	76,1	166	153	3309	
80	88,9	194	179	3310	
100	108	240	222	3311	