

Bend 45° Male-Male

Manufacturing standards: DVGW round tubes manufactured according to DIN-1988/2463 EN 10312 Tubes with DVGW TS 225 approval correspond to the requirements of DVGW worksheet W 541

Certificates: Standard supply in lengths of 6 m. We provide product certificates if required, according to the following standard: EN 10204/3.1.B or DIN 50049.

Grades: Austenitic grades types 304-L, 316-L

Dimensions: Manufactured in diameters from 15 mm to 108 mm. Wall thicknesses from 1 to 2 mm

Applications: DVGW W 541 tubes are used in the transport of drinking and chlorinated water up to 2 mg/l in water with AISI-316 L pipes, AISI-304 L quality is used in compressed air installations.



Technical information

DN	Dimensiones			Art.
	Tubo Ø	L	L1	
12	15	52	120	0872
15	18	58	124	0873
20	22	56	120	0874
25	28	58	122	0875
32	35	94	206	0876
40	42	114	262	0877
50	54	146	321	0878
65	76,1	225	225	0879
80	88,9	267	267	0880
100	108	293	293	0881