

Reducing Male-Female


Manufacturing standards: DVGW round tubes manufactured according to DIN-1988/2463 EN 10312 Tubes with DVGW TS 225 approval correspond to the requirements of DVGW worksheet W 541

Certificates: Standard supply in lengths of 6 m. We provide product certificates if required, according to the following standard: EN 10204/3.1.B or DIN 50049.

Grades: Austenitic grades types 304-L, 316-L

Dimensions: Manufactured in diameters from 15 mm to 108 mm. Wall thicknesses from 1 to 2 mm

Applications: DVGW W 541 tubes are used in the transport of drinking and chlorinated water up to 2 mg/l in water with AISI-316 L pipes, AISI-304 L quality is used in compressed air installations.



Technical information

DN	Dimensiones		Art.
	Tubo Ø	L	
15-12	18-15	55	2303
20-12	22-15	59	2305
20-15	22-18	57	2306
25-12	28-15	66	2307
25-15	28-18	64	2308
25-20	28-22	60	2309
32-12	35-15	75	2310
32-15	35-18	74	2311
32-20	35-22	7,1	2312
32-25	35-28	6,8	2313
40-12	42-15	8,1	2314
40-15	42-18	8	2315
40-20	42-22	8,2	2316
40-25	42-28	8,3	2317
40-32	42-35	7,7	2318
50-12	54-15	9,7	2319

50-15	54-18	9,6	2320
50-25	54-28	11	2322
50-32	54-35	10,6	2323
50-40	54-42	9,2	2324
65-50	76,1-54	14,6	2331
80-50	88,9-54	16,3	2338
80-65	88,9-76,1	16,1	2339
100-50	108-54	17,2	2345
100-65	108-76,1	18,4	2346
100-80	108-88,9	20,3	2348